

## TEST REPORT

**Test Object:** Cap and pin type glass insulator  
**Designation:** 52-8  
**Manufacturer:** Lviv Insulator Company Ltd.  
79000 Lviv, Zelena Srt. 301  
Ukraine  
**Tested for:** Lviv Insulator Company Ltd.  
**Date of tests:** 1<sup>st</sup> October 2012 – 20<sup>th</sup> November 2012  
**Tested by:** VEIKI-VNL Electric Large Laboratories Ltd.  
**Project ID:** NFL-30/2012/A1  
**Order/Contract:** NFL-30/2012, 27<sup>th</sup> July 2012  
**Test Specification:** ANSI C29-1:1988  
ANSI C29-2:1992  
**Tests Performed:** The test object, constructed in accordance with the description, drawing and photographs incorporated in this report has been subjected to Quality conformance tests and Design tests.  
**Test Results:** The test object fulfilled the relevant requirements of the standard.

This Type Tests Report has been issued by VEIKI-VNL Ltd. in accordance with above mentioned Specifications.

The Report applies only to the test object tested. The responsibility for conformity of any test object having the same designations with that tested rests with the Manufacturer.


This Report comprises 24 sheets in total (22 numbered pages, 1 drawing;).


Only integral reproduction of this document is permitted without written permission from VEIKI-VNL Ltd.


VEIKI-VNL Ltd. is an independent testing laboratory accredited by the Hungarian Accreditation Board (NAT) under registration no. NAT-1-1251/2011.



Budapest  
27<sup>th</sup> November, 2012

  
Tamás Forgó  
responsible for the test

  
Péter Szél  
supervised by

  
Dr. László Varga  
managing director

H-1158 Budapest, Vasgolyó u. 2-4.

E-mail: vnl@vnl.hu  
www. vnl.hu

Phone: +36-1-417 3157  
Fax: +36-1-417 3163