

TYPE TEST REPORT

Test object: Cap and pin type glass insulator
Designation: Cap and pin type ANSI 52-3 glass insulator
Manufacturer: Lviv Insulator Company,Ltd.
79000 Lviv, Zelena Srt. 301 - UKRAINE
Tested for: Lviv Insulator Company,Ltd.
Date of tests: 17th April, 2014
Tested by: VEIKI-VNL Ltd. – Budapest – HUNGARY
Project ID: NFL-11 / 2014
Order/Contract: NFL-11 / 2014; 19th March, 2014
Test specification: IEC 61467:2008, Clause 8
Tests performed: The test object, constructed in accordance with the description, drawing and photographs incorporated in this report has been subjected to **power arc tests**.
Test results: The tested cap and pin glass insulators fulfilled the prescription of the referred IEC standard concerning to power arc tests on short strings with parameters of 6 kA-0.2s.
The test object fulfilled the requirements of the standard.


This Type Test Report has been issued by VEIKI-VNL Ltd. in accordance with above mentioned specification.


The Report applies only to the test object. The responsibility for conformity of any product having the same designations with that tested rests with the Manufacturer.


This Report comprises 17 sheets in total (13 numbered pages, 1 drawing and 3 oscillograms). Only integral reproduction of this document is permitted without written permission from VEIKI-VNL Ltd.



Budapest,
26th May, 2014


Ferenc Bukor
responsible for the test


László Tóth
supervised by


Dr. László Varga
managing director